

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 507/D/SWA/NSA

Dated: 21/9/2026

It is certified that an inspection team headed by AIKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAMPHED

inspected the ST. JOSEPH'S SR. SEC. SCHOOL, Defence Colony, Kanpur

(Name & Address of the school) on 15/9/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 437/SWA/CHEM dated 21/9/2026

of Public Health Laboratory K.N.N. (PHED Lab) certified that

the ST. JOSEPH'S SR. SEC. SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To ST. JOSEPH'S SR. SEC. SCHOOL  
Defence Colony, Kanpur, Taj mahal.  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

67 | Page

[Signature]  
PRINCIPAL  
ST. JOSEPH'S SR. SEC. SCHOOL  
KANPUR U.P.-208010

[Signature]  
MANAGER  
ST. JOSEPH'S SR. SEC. SCHOOL  
KANPUR, U.P. - 208010



# KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the ST. JOSEPH'S SR. SEC. SCHOOL, Defence Colony Kanpur Nagar

Sample taken from — — — SUBMERGIBLE — — —

Date of sample Drawn — — — 15/9/2026 — — —

Date of analysis — — — 15/9/2026 — — —

Physical Character — — — TRANSPARENT / ODORLESS — — —

P. H. Value — — — 8.46 — — —

Free Ammonia Parts per 1000000 — — — NIL — — —

Albuminoid Ammonia Part per 1000000 — — — NIL — — —

Oxygen absorbed from pot. Permagnate in three hours at 37° C — — — 0.4 — — —

Chloride Part per 1000000 — — — 150.00 — — —

Nitrates Parts per 1000000 — — — TRACES — — —

Nitrates Parts per 1000000 — — — TRACES — — —

Total solid part per 100000 — — — 1120.00 — — —

Fixed solid Parts per 1000000 — — — 904.00 — — —

Volatils solid Parts per 100000 — — — 216.00 — — —

Appearance on ignition — — — NO CHANGING — — —


Total hardness Parts per 1000000 — — — 496.00 — — —

Permanent hardness Parts per 1000000 — — — 420.00 — — —

Temporary hardness Parts per 1000000 — — — 60.00 — — —

Remarks :

POTABLE



PRINCIPAL

ST. JOSEPH'S SR. SEC. SCHOOL

KANPUR, U.P. - 208010

No. 437/15/2026 dated 21/09/2026

Copy forwarded for favour or information to



MANAGER

ST. JOSEPH'S SR. SEC. SCHOOL  
KANPUR, U.P. - 208010

St. Joseph's Sr. Sec. School,  
Defence Colony, Kanpur Tajman

N.S.A. Kanpur Nagar Nigam

Nagar Swasthya Raksha Mahini  
Nagar Nigam Kanpur

जल सुरक्षा  
कमिटी

नगर निगम कांपुर



# KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from

St. Joseph's Sr. Sec. School, Defence Colony, Kanpur

Name & designation of the person collecting samples

AKA SENGH - CHEMIST

| Date & time of collection | Source of sample | Colony count on Agar Agar per M. L. of water |                                 | Presumptive Coliform count                            |        |         |        | Probable on of coliform organism in 100 CC of original water | Free Residual Chlorine part per Million | REMARKS         |
|---------------------------|------------------|----------------------------------------------|---------------------------------|-------------------------------------------------------|--------|---------|--------|--------------------------------------------------------------|-----------------------------------------|-----------------|
|                           |                  | at 37.c in 48 hours                          | at room temperature in 72 hours | Quantity of water put in each tube No of tubes put up | 50ML 1 | 10 ML 5 | 1 ML 5 |                                                              |                                         |                 |
| 15/9/2026                 | Summersale '22'  | 86'                                          | —                               | —                                                     | —      | 2'      | 2'     | Zero'                                                        | Nil                                     | Do Chlorination |

Remarks - Chlorination is very necessary for Disinfection / F.R.C. must be 0.2 ppm

Copy for Information Forwarded to


- (1) St. Joseph's Sr. Sec. School  
Defence Colony, Kanpur
- (2) N.S.A. Kanpur Nagar Nigam



PRINCIPAL  
ST. JOSEPH'S SR. SEC. SCHOOL  
KANPUR U.P.-208010



MANAGER  
ST. JOSEPH'S SR. SEC. SCHOOL  
KANPUR, U.P. - 208010

  
अलका सिंह नगर निगम कानपुर  
केमिस्ट  
नगर निगम कानपुर